

Northumberland Dock Road, Wallsend, Tyne & Wear, NE28 0QD | www.nwss-labs.co.uk

Tel: 0333 3214932 | Email: nwsscuser@nwl.co.uk

 Customer: [REDACTED]
 North Yorkshire Council

 Address: 1 Belle Vue Square Broughton Road
 Skipton

 Contract Reference: NORTH_YORK-05770
 Contract Description: Private Water Supply Sampling - Craven
 Project Manager: [REDACTED] (Horsley)

Postcode: BD23 1FJ

 Lab Number: 3194126
 Date & Time Taken: 08/05/25 11:45
 Sample Matrix: DW - Drinking Water

 Sample Name: P28(3)1 - Pre-treatment, Riverside Caravan
 Park, Bentham, LA2 7FJ
 Date Received: 08/05/25 Date Started: 08/05/25

 Sample Comments: PFASDWI_WA - PFAS results deviating
 Collected From:

PARAMETER	RESULTS	METHOD	SITE
D 3:3 FTCA	<0.009 ug/l	Sub-Contracted	SU
D 4:2 FTSA	<0.004 ug/l	Sub-Contracted	SU
D 5:3 FTCA	<0.005 ug/l	Sub-Contracted	SU
D 6:2 CI-PFESA	<0.002 ug/l	Sub-Contracted	SU
* 6:2 FTAB	<0.005 ug/l	Sub-Contracted	SU
D 6:2 FTSA	<0.005 ug/l	Sub-Contracted	SU
D 7:3 FTCA	<0.007 ug/l	Sub-Contracted	SU
D 8:2 CI-PFESA	<0.004 ug/l	Sub-Contracted	SU
D 8:2 FTSA	<0.004 ug/l	Sub-Contracted	SU
D DONA	<0.003 ug/l	Sub-Contracted	SU
D EtFOSA	<0.005 ug/l	Sub-Contracted	SU
D EtFOSE	<0.003 ug/l	Sub-Contracted	SU
D FBSA	<0.005 ug/l	Sub-Contracted	SU
D FHxSA	<0.003 ug/l	Sub-Contracted	SU
D FOSA	<0.004 ug/l	Sub-Contracted	SU
D HFPO-DA	<0.008 ug/l	Sub-Contracted	SU
D HFPO-TA	<0.004 ug/l	Sub-Contracted	SU
D MeFOSA	<0.007 ug/l	Sub-Contracted	SU
D MeFOSE	<0.004 ug/l	Sub-Contracted	SU
D NEtFOSAA	<0.005 ug/l	Sub-Contracted	SU
D NFDHA	<0.005 ug/l	Sub-Contracted	SU

Authorised By:

 [REDACTED]
 Laboratory Team
 Leader

This report was compiled by the Customer Department

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation

Date of issue: 05/06/25

Results relate only to the items tested and are reported without Uncertainty of Measurement (UOM) applied. UOM data is available upon request.

Tests marked * in this report are NOT included in the UKAS accreditation schedule for this laboratory. Tests marked 'D' in this report ARE included in the DWTS accreditation schedule for this laboratory.

Tests marked HN analysed at Howdon Laboratory, Northumberland Dock Road, Wallsend, Tyne & Wear, NE28 0QD

Tests marked HY analysed at Horsley Laboratory, Horsley, Newcastle upon Tyne, NE15 0PE

Tests marked CD analysed at Chelmsford Laboratory, Middlemead, South Hanningfield, Chelmsford, Essex, CM3 8HS

Tests marked OS analysed On-Site Tests marked SU analysed by subcontractor

Northumberland Dock Road, Wallsend, Tyne & Wear, NE28 0QD | www.nwss-labs.co.uk

Tel: 0333 3214932 | Email: nwsscuser@nwl.co.uk

Customer: [REDACTED]
North Yorkshire Council

Address: 1 Belle Vue Square Broughton Road
Skipton

Contract Reference: NORTH_YORK-05770
Contract Description: Private Water Supply Sampling - Craven
Project Manager: [REDACTED] (Horsley)

Postcode: BD23 1FJ

Lab Number: 3194126
Date & Time Taken: 08/05/25 11:45
Sample Matrix: DW - Drinking Water

Sample Name: P28(3)1 - Pre-treatment, Riverside Caravan
Park, Benthams, LA2 7FJ
Date Received: 08/05/25 **Date Started:** 08/05/25

Sample Comments: PFASDWI_WA - PFAS results deviating
Collected From:

PARAMETER	RESULTS	METHOD	SITE
D NMeFOSAA	<0.003 ug/l	Sub-Contracted	SU
D PFBA	<0.001 ug/l	Sub-Contracted	SU
D PFBS	<0.003 ug/l	Sub-Contracted	SU
D PFDA	<0.003 ug/l	Sub-Contracted	SU
D PFDaA	<0.004 ug/l	Sub-Contracted	SU
D PFDoS	<0.005 ug/l	Sub-Contracted	SU
D PFDS	<0.005 ug/l	Sub-Contracted	SU
D PFecHS	<0.004 ug/l	Sub-Contracted	SU
D PFEESA	<0.002 ug/l	Sub-Contracted	SU
D PFHpA	<0.003 ug/l	Sub-Contracted	SU
D PFHpS	<0.003 ug/l	Sub-Contracted	SU
D PFHxA	<0.002 ug/l	Sub-Contracted	SU
D PFHxDA	<0.004 ug/l	Sub-Contracted	SU
D PFHxS	<0.005 ug/l	Sub-Contracted	SU
D PFMOBA	<0.003 ug/l	Sub-Contracted	SU
D PFMOPrA	<0.002 ug/l	Sub-Contracted	SU
D PFNA	<0.003 ug/l	Sub-Contracted	SU
D PFNS	<0.005 ug/l	Sub-Contracted	SU
D PFOA	<0.003 ug/l	Sub-Contracted	SU
D PFODA	<0.004 ug/l	Sub-Contracted	SU
D PFOS	<0.002 ug/l	Sub-Contracted	SU
D PFPeA	<0.002 ug/l	Sub-Contracted	SU

Authorised By: [REDACTED]

[REDACTED]
Laboratory Team
Leader

This report was compiled by the Customer Department

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation

Results relate only to the items tested and are reported without Uncertainty of Measurement (UOM) applied. UOM data is available upon request.

Date of issue: 05/06/25

Tests marked * in this report are NOT included in the UKAS accreditation schedule for this laboratory. Tests marked 'D' in this report ARE included in the DWTS accreditation schedule for this laboratory.

Tests marked HN analysed at Howdon Laboratory, Northumberland Dock Road, Wallsend, Tyne & Wear, NE28 0QD
Tests marked HY analysed at Horsley Laboratory, Horsley, Newcastle upon Tyne, NE15 0PE
Tests marked CD analysed at Chelmsford Laboratory, Middlemead, South Hanningfield, Chelmsford, Essex, CM3 8HS
Tests marked OS analysed On-Site Tests marked SU analysed by subcontractor

Certificate No. - 3194126-1

RR: 9586

R0001 V.1.1.19

Page 2 of 3

Northumberland Dock Road, Wallsend, Tyne & Wear, NE28 0QD | www.nwss-labs.co.uk

Tel: 0333 3214932 | Email: nwsscuster@nwl.co.uk

Customer: [REDACTED]
North Yorkshire Council

Address: 1 Belle Vue Square Broughton Road
Skipton

Contract Reference: NORTH_YORK-05770
Contract Description: Private Water Supply Sampling - Craven
Project Manager: [REDACTED] (Horsley)

Postcode: BD23 1FJ

Lab Number: 3194126
Date & Time Taken: 08/05/25 11:45
Sample Matrix: DW - Drinking Water

Sample Name: P28(3)1 - Pre-treatment, Riverside Caravan
Park, Bentham, LA2 7FJ

Date Received: 08/05/25 **Date Started:** 08/05/25

Sample Comments: PFASDWI_WA - PFAS results deviating
Collected From:

PARAMETER	RESULTS	METHOD	SITE
D PFPeS	<0.004 ug/l	Sub-Contracted	SU
D PFTeA	<0.005 ug/l	Sub-Contracted	SU
D PFTrDA	<0.003 ug/l	Sub-Contracted	SU
D PFUnA	<0.004 ug/l	Sub-Contracted	SU
D PFUnDS	<0.007 ug/l	Sub-Contracted	SU
D total PFAS	0 ug/l	Sub-Contracted	SU

Please find below the list of incident report references relating to this sample. Each separate incident report detailed must be reviewed with the main analytical report. Please Contact the Customer Team if you have queries regarding any of these reports.

3194126_8/5__99

Authorised By: [REDACTED]

[REDACTED]
Laboratory Team
Leader

This report was compiled by the Customer Department

Date of issue: 05/06/25

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation

Results relate only to the items tested and are reported without Uncertainty of Measurement (UOM) applied. UOM data is available upon request.

Tests marked * in this report are NOT included in the UKAS accreditation schedule for this laboratory. Tests marked 'D' in this report ARE included in the DWTS accreditation schedule for this laboratory.

Tests marked HN analysed at Howdon Laboratory, Northumberland Dock Road, Wallsend, Tyne & Wear, NE28 0QD
Tests marked HY analysed at Horsley Laboratory, Horsley, Newcastle upon Tyne, NE15 0PE
Tests marked CD analysed at Chelmsford Laboratory, Middlemead, South Hanningfield, Chelmsford, Essex, CM3 8HS
Tests marked OS analysed On-Site Tests marked SU analysed by subcontractor