

Northumberland Dock Road, Wallsend, Tyne & Wear, NE28 0QD

Tel: 0191 2968366 Fax: 0191 2968560 www.nwss-labs.co.uk

Customer: [REDACTED]
North Yorkshire Council

Address: 1 Belle Vue Square Broughton Road
Skipton

Contract Reference: NORTH_YORK-05770

Contract Description: Private Water Supply Sampling - Craven

Postcode: BD23 1FJ

Project Manager: [REDACTED] (Horsley)

Lab Number: 2936749

Date & Time Taken: 22/03/24 12:00

Sample Name: 2831 - Riverside Caravan Park, Bentham, LA2 7FJ

Date Received: 22/03/24

Date Started: 22/03/24

PFASDWI_WA - PFMOPrA & 6:2 FTSA analysis exceeds ISO5667-3 stability targets

Sample Point:

Collected From:

PARAMETER	RESULTS	METHOD	SITE
E.coli	0 /100ml	HY-073	HY
total coliforms	0 /100ml	HY-073	HY
3:3 FTCA	<0.009 ug/l	Sub-Contracted	SU
4:2 FTSA	<0.004 ug/l	Sub-Contracted	SU
5:3 FTCA	<0.005 ug/l	Sub-Contracted	SU
6:2 CI-PFESA	<0.002 ug/l	Sub-Contracted	SU
6:2 FTSA	<0.005 ug/l	Sub-Contracted	SU
7:3 FTCA	<0.007 ug/l	Sub-Contracted	SU
8:2 CI-PFESA	<0.004 ug/l	Sub-Contracted	SU
8:2 FTSA	<0.004 ug/l	Sub-Contracted	SU
DONA	<0.003 ug/l	Sub-Contracted	SU
EtFOSA	<0.005 ug/l	Sub-Contracted	SU
EtFOSE	<0.003 ug/l	Sub-Contracted	SU
FBSA	<0.005 ug/l	Sub-Contracted	SU
FHxSA	<0.003 ug/l	Sub-Contracted	SU
FOSA	<0.004 ug/l	Sub-Contracted	SU
HFPO-DA	<0.008 ug/l	Sub-Contracted	SU
HFPO-TA	<0.004 ug/l	Sub-Contracted	SU
MeFOSA	<0.007 ug/l	Sub-Contracted	SU
MeFOSE	<0.004 ug/l	Sub-Contracted	SU
NEtFOSAA	<0.005 ug/l	Sub-Contracted	SU

Authorised By:

[REDACTED]
Laboratory Team
Leader

Under the authority of
Ian Barnabas
Head of Laboratories and Sampling

This report was compiled by the Customer Department

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation

Date of issue: 04/04/24

Results relate only to the items tested and are reported without Uncertainty of Measurement (UOM) applied. UOM data is available upon request.

Tests marked HN analysed at Howdon Laboratory, Northumberland Dock Road, Wallsend, Tyne & Wear, NE28 0QD

Tests marked HY analysed at Horsley Laboratory, Horsley, Newcastle upon Tyne, NE15 0PE

Tests marked CD analysed at Chelmsford Laboratory, Middlemead, South Hanningfield, Chelmsford, Essex, CM3 8HS

Tests marked OS analysed On-Site Tests marked SU analysed by subcontractor

Northumberland Dock Road, Wallsend, Tyne & Wear, NE28 0QD

Tel: 0191 2968366 Fax: 0191 2968560 www.nwss-labs.co.uk

Customer: [REDACTED]
North Yorkshire Council

Address: 1 Belle Vue Square Broughton Road
Skipton

Contract Reference: NORTH_YORK-05770

Contract Description: Private Water Supply Sampling - Craven

Postcode: BD23 1FJ

Project Manager: [REDACTED] (Horsley)

Lab Number: 2936749

Date & Time Taken: 22/03/24 12:00

Sample Name: 2831 - Riverside Caravan Park, Bentham, LA2 7FJ

Date Received: 22/03/24

Date Started: 22/03/24

PFASDWI_WA - PFMOPrA & 6:2 FTSA analysis exceeds ISO5667-3 stability targets

Sample Point:

Collected From:

PARAMETER	RESULTS	METHOD	SITE
NFDHA	<0.005 ug/l	Sub-Contracted	SU
NMeFOSAA	<0.003 ug/l	Sub-Contracted	SU
PFBA	<0.001 ug/l	Sub-Contracted	SU
PFBS	<0.003 ug/l	Sub-Contracted	SU
PFDA	<0.003 ug/l	Sub-Contracted	SU
PFDaA	<0.004 ug/l	Sub-Contracted	SU
PFDoS	<0.005 ug/l	Sub-Contracted	SU
PFDS	<0.005 ug/l	Sub-Contracted	SU
PFecHS	<0.004 ug/l	Sub-Contracted	SU
PFEESA	<0.002 ug/l	Sub-Contracted	SU
PFHpA	<0.003 ug/l	Sub-Contracted	SU
PFHpS	<0.003 ug/l	Sub-Contracted	SU
PFHxA	<0.002 ug/l	Sub-Contracted	SU
PFHxDA	<0.004 ug/l	Sub-Contracted	SU
PFHxS	<0.005 ug/l	Sub-Contracted	SU
PFMOBA	<0.003 ug/l	Sub-Contracted	SU
PFMOPrA	<0.002 ug/l	Sub-Contracted	SU
PFNA	<0.003 ug/l	Sub-Contracted	SU
PFNS	<0.005 ug/l	Sub-Contracted	SU
PFOA	<0.003 ug/l	Sub-Contracted	SU
PFODA	<0.004 ug/l	Sub-Contracted	SU
PFOS	<0.002 ug/l	Sub-Contracted	SU

Authorised By:

[REDACTED]
Laboratory Team
Leader

Under the authority of
Ian Barnabas
Head of Laboratories and Sampling

This report was compiled by the Customer Department

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation

Date of issue: 04/04/24

Results relate only to the items tested and are reported without Uncertainty of Measurement (UOM) applied. UOM data is available upon request.

Tests marked HN analysed at Howdon Laboratory, Northumberland Dock Road, Wallsend, Tyne & Wear, NE28 0QD

Tests marked HY analysed at Horsley Laboratory, Horsley, Newcastle upon Tyne, NE15 0PE

Tests marked CD analysed at Chelmsford Laboratory, Middlemead, South Hanningfield, Chelmsford, Essex, CM3 8HS

Tests marked OS analysed On-Site Tests marked SU analysed by subcontractor

Northumberland Dock Road, Wallsend, Tyne & Wear, NE28 0QD

Tel: 0191 2968366 Fax: 0191 2968560 www.nwss-labs.co.uk

Customer: [REDACTED]
North Yorkshire Council

Address: 1 Belle Vue Square Broughton Road
Skipton

Contract Reference: NORTH_YORK-05770

Contract Description: Private Water Supply Sampling - Craven

Postcode: BD23 1FJ

Project Manager: [REDACTED] (Horsley)

Lab Number: 2936749

Date & Time Taken: 22/03/24 12:00

Sample Name: 2831 - Riverside Caravan Park, Bentham, LA2 7FJ

Date Received: 22/03/24

Date Started: 22/03/24

PFASDWI_WA - PFMOPrA & 6:2 FTSA analysis exceeds ISO5667-3 stability targets

Sample Point:

Collected From:


PARAMETER	RESULTS	METHOD	SITE
PFPeA	<0.002 ug/l	Sub-Contracted	SU
PFPeS	<0.004 ug/l	Sub-Contracted	SU
PFTeA	<0.005 ug/l	Sub-Contracted	SU
PFTTrDA	<0.003 ug/l	Sub-Contracted	SU
PFUnA	<0.004 ug/l	Sub-Contracted	SU
PFUnDS	<0.007 ug/l	Sub-Contracted	SU
total PFAS	0 ug/l	Sub-Contracted	SU

Sampling Methods used: L1

Please find below the list of incident report references relating to this sample. Each separate incident report detailed must be reviewed with the main analytical report. Please Contact the Customer Team if you have queries regarding any of these reports.

2936749_22/3_50

Authorised By:



[REDACTED]
Laboratory Team
Leader

Under the authority of
Ian Barnabas
Head of Laboratories and Sampling

This report was compiled by the Customer Department

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation

Date of issue: 04/04/24

Results relate only to the items tested and are reported without Uncertainty of Measurement (UOM) applied. UOM data is available upon request.

Tests marked HN analysed at Howdon Laboratory, Northumberland Dock Road, Wallsend, Tyne & Wear, NE28 0QD

Tests marked HY analysed at Horsley Laboratory, Horsley, Newcastle upon Tyne, NE15 0PE

Tests marked CD analysed at Chelmsford Laboratory, Middlemead, South Hanningfield, Chelmsford, Essex, CM3 8HS

Tests marked OS analysed On-Site Tests marked SU analysed by subcontractor